


PULSE GENERATOR
PERFORMANCE CHECK

Model: AVP-25-P-05-ECL

S.N.: 6877

Date: DEC. 9/93



- a) Output signal amplitude:
0 TO +2 VOLTS
- b) Pulse width:
0.2 TO 4.0 NS
- c) Rise time:
≤ 40 PS
- d) Fall time:
≤ 135 PS
- e) PRF:
0 TO 1.0 MHz
- f) Jitter, stability:
OK
- g) Prime power:
+15 VOLTS
400 mA (MAX)

20 db ATTEN
∴ 2 VOLTS/DIV
PRF = 1.0 MHz

$$TRT = \sqrt{T_{R25}^2 + T_{SCOPE}^2 + T_{ATTEN}^2}$$
$$\approx 50 \text{ PS (20-80\%)}$$

SCOPE = 25 PS

18 GHz ATTEN + CABLES

∴ CONCL THAT $T_{R25} \leq 40 \text{ PS}$