

PULSE GENERATOR
PERFORMANCE CHECK

Model: *AVR-7B-B-P*
S.N.: *9301*
Date: *MAY 5 2000*



- a) Output signal amplitude:
0 TO +700 VOLTS
- b) Pulse width: *($R_L \geq 50 \Omega$)*
0.1 TO 100 μ S
- c) Rise time: *(0.59. MAX DUTY CYCLE)*
 ≤ 50 NS
- d) Fall time:
 ≤ 50 NS
- e) PRF: *0 TO 10 KHZ*
(0.59. MAX DUTY CYCLE)
- f) Jitter, stability: *OK*
- g) Prime power: *120/240 V*
50-60 HZ.

[Signature]



9301

NARROW PULSE

$$R_i = 50 \Omega$$



9301
WIDE PULSE
 $R_L = 50\Omega$





AVTECH ELECTROSYSTEMS LTD.

NANOSECOND WAVEFORM ELECTRONICS
SINCE 1975

P. O. BOX 265
OGDENSBURG, NY
U.S.A. 13669-0265
TEL: (315) 472-5270
FAX: (613) 226-2802

TEL: 1-800-265-6681
FAX: 1-800-561-1970

e-mail: info@avtechpulse.com
http://www.avtechpulse.com

P.O. BOX 5120 STN. F
OTTAWA, ONTARIO
CANADA K2C 3H4
TEL: (613) 226-5772
FAX: (613) 226-2802

"-B" Functional Test & Calibration Certificate

Date of test:	May 5, 2000				Tester:	MJC
Programmed model name:	AVR-7B-B-P					
Programmed serial number:	9301					
Firmware revision:	2.11					
Internal trigger checked at:	1 Hz	100 Hz	1 kHz	10 kHz		
Actual measured output ¹ :	1.008 Hz	100.9 Hz	1.006 kHz	10.03 kHz		
External trigger checked:	yes			Gate checked:	yes	
Trigger load resistor present:	200 Ohms					
Manual trigger checked:	yes					
Pulse compression checked:	yes					
Pulse width checked at:	100 ns	1 us	10 us	100 us	5 Hz, +700V, into 50 Ohms	
Actual measured output ² :	102.5 ns	0.988 us	10.0 us	100.5 us		
PWin = PWout mode checked:	yes			DC mode checked:	N/A	
Duty Cycle Limit:	0.5%					
Delay nulled:	yes					
Delay checked at:	100 ns	1 us	10 us	100 us	10 Hz, +700V, into 50 Ohms	
Actual measured output ¹ :	100.2 ns	1.001 us	10.07 us	100.4 us		
Double pulse checked:	N/A					
Invert mode checked:	N/A					
ECL/TTL modes checked:	N/A					
Zout switch checked:	N/A					
Amplitude checked at:	+100V	+300V	+500V	+700V	10 Hz, 1 us PW, 50 Ohms	
Actual measured output ² :	+101.6V	+304V	+507V	+702V		
Amplitude polarity:	+					
Zout calibration:	N/A					
Electronic amplitude control:	N/A					
External amplify mode:	N/A					
Ultraviolet flux removed:	N/A					
Monitor V/I Ratio:	N/A			Monitor offset nulled:		
LCD Monitor calibrated:	N/A			Monitor offset nulled:		
Mon. Single Pulse/Min PW OK:	N/A			SHA Cap:		
Offset checked at:	N/A					
Actual measured output ² :	N/A					
Offset nulled (output on):	N/A			Amplitude-dependent offset nulled:		
Offset nulled (output off):	N/A					
RS-232 checked:	yes					
Sync pulse width checked:	50 ns (special modification at customer request - normally 200 ns)					
Circuit Boards:	PS:	93	Main:	86		
Overload Trigger Resistance:	Trips at:	N/A	Installed:	1.5k		
DC fuses:	Positive:	2.5A	Negative:	N/A		
AC Current at 115 VAC:	Quiescent:	0.37A	Max. Load:	1.1A		
AC fuse:	2A					
Photographed:	yes					

¹ Checked with: HP5370A Universal Time Interval Counter

² Checked with: Tektronix TDS360 digital oscilloscope for PW ≥ 5 ns,
Tektronix 7704A/7S11/7T11/S4 sampling oscilloscope system for PW < 5 ns.