

PULSE GENERATOR  
PERFORMANCE CHECK

Model: *AV-106B-B-P-SPSLA*

S.N.: *9809*

Date: *JULY 12 2001*

- a) Output signal amplitude:  
*0 TO +50 VPP*
- b) Pulse width:  
*2 TO 50  $\mu$ S*
- c) Rise time:  
*5% MAX DUTY CYCLE*  
 *$\leq 1.45^*$*
- d) Fall time:  
 *$\leq 1.45^*$*
- e) PRF:  
*0 TO 1 KHz*
- f) Jitter, stability:  
*5% MAX DUTY CYCLE*  
*OK*
- g) Prime power:  
*120/240 V*  
*50/60 Hz*

*[Signature]*  
\* RISE TIME OF MONITOR  
CIRCUIT IS ABOUT 2  $\mu$ S.

(A)

9809


MAX AMPLITUDE

MAX DUTY CYCLE

$R_L \approx 0.145 \Omega$

PRF = 1 kHz

PW = 500  $\mu$ s



NOTE RISE TIME OF  
MONITOR CIRCUIT  
IS ABOUT 2  $\mu$ s.

(B)

9809

$$I_p = 20 \text{ Amps}$$

MAX DUTY CYCLE


$$R_c = 0.145 \Omega$$

$$PRF = 1 \text{ KHz}$$

$$PW = 50 \mu\text{s}$$

LOAD VOLTAGE

MONITOR VOLTAGE



©

9809


$I_0 \approx 5 \text{ Amps}$

MAX DUTY CYCLE

$R_L \approx 0.145 \Omega$

PRF = 1 kHz

PW = 50  $\mu$ s.





# AVTECH ELECTROSYSTEMS LTD.

NANOSECOND WAVEFORM ELECTRONICS  
SINCE 1975

P.O. BOX 265  
OGDENSBURG, NY  
U.S.A. 13669-0265  
TEL: (315) 472-5270  
FAX: (613) 226-2802

TEL: 1-800-265-6681  
FAX: 1-800-561-1970

e-mail: info@avtechpulse.com  
http://www.avtechpulse.com

P.O. BOX 5120 STN. F  
OTTAWA, ONTARIO  
CANADA K2C 3H4  
TEL: (613) 226-5772  
FAX: (613) 226-2802

## "-B" Functional Test & Calibration Certificate

Date of test:	July 12, 2001				Tester:	MJC
Programmed model name:	AV-106B-B-P-SPSLA					
Programmed serial number:	9809					
Firmware revision:	2.26					
Internal trigger checked at:	1 Hz	10 Hz	100 Hz	1 kHz		
Actual measured output <sup>1</sup> :	1.000 Hz	9.997 Hz	99.92 Hz	0.999 kHz		
External trigger checked:	yes			Gate checked:	yes	
Manual trigger checked:	yes					
Pulse compression checked:	yes	Low Amplitude PW Distortion Nulled:			N/A	
Pulse width checked at:	2 us	10 us	50 us		10 Hz, +5A to 0.164 Ohms	
Actual measured output <sup>2</sup> :	1.997 us	9.97 us	50.48 us			
PWin = PWout mode checked:	yes			DC mode checked:	N/A	
Duty Cycle Limit:	5%					
Delay nulled:	N/A					
Delay checked at:	100 ns	1 us	10 us	200 us	TTL trigger to SYNC	
Actual measured output <sup>1</sup> :	99.0 ns	1.000 us	9.99 us	201.6 us		
Double pulse checked:	N/A					
Invert mode checked:	N/A					
ECL/TTL modes checked:	N/A					
Zout switch checked:	N/A					
Amplitude checked at:	+2A	+10A	+20A	+50A	10 Hz, 50 us to 0.164 Ohms	
Actual measured output <sup>2</sup> :	+2.01A	+9.94A	+19.6A	+50.0A		
Amplitude polarity:	+					
Zout calibration:	N/A					
Electronic amplitude control:	N/A					
External amplify mode:	N/A					
Ultravolt flux removed:	N/A					
Monitor V/I Ratio:	9.4 mV/A		Monitor offset nulled:		N/A	
LCD Monitor calibrated:	N/A		Monitor offset nulled:		N/A	
Offset checked at:	N/A					
Actual measured output <sup>2</sup> :	N/A					
Offset nulled (output on):	N/A			Amplitude-dependent offset nulled:		
Offset nulled (output off):	N/A					
RS-232 checked:	yes					
Sync pulse width checked:	200 ns					
Circuit Boards:	PS:	93	Main:	108B		
Overload Trigger Resistance:	Trips at:	N/A	Installed:	2.2k		
DC fuses:	Positive:	2.5A	Negative:	N/A		
AC Current at 115 VAC:	Quiescent:	0.52A	Max. Load:	1.55A		
AC fuse:	2A					
Photographed:	yes					

<sup>1</sup> Checked with: Fluke PM6681 Counter, referenced to Datum ExacTime 9390-6000 GPS Frequency Reference

<sup>2</sup> Checked with: Tektronix TDS3052 digital oscilloscope for PW ≥ 5 ns,  
Tektronix 7704A/7S11/7T11/S4 sampling oscilloscope system for PW < 5 ns.