


PULSE GENERATOR
PERFORMANCE CHECK

Model: AVPP-2-B-P

S.N.: 10783

Date: NOV 24 2003




- a) Output signal amplitude: 0 TO +20 V (TO 50Ω)
- b) Pulse width: 0.4 TO 100 NS
- c) Rise time: ≤ 200 ps
- d) Fall time: ≤ 300 ps
- e) PRF: 0 TO 100 KHz
- f) Jitter, stability: OK

0.4 TO 6.5 NS RANGE 40 dB ATTN
--10V/DIV

TOP: 1 NS/DIV

BOT: 200 ps/DIV (RISE TIME)

- g) Prime power: 120/240 V
50-60 Hz



← 5 NS/DIV

← 200 ps/DIV (RISE TIME)

← 200 ps/DIV (FALL TIME)

6.5 TO 100 NS RANGE 10V/DIV

PRF = 100 KHz

AVTECH**AVTECH ELECTROSYSTEMS LTD.**
 NANOSECOND WAVEFORM ELECTRONICS
 SINCE 1975

 P.O. BOX 265
 OGDENSBURG, NY
 U.S.A. 13669-0265
 TEL: (315) 472-5270
 FAX: (613) 226-2802

 TEL: 1-800-265-6681
 FAX: 1-800-561-1970

 e-mail: info@avtechpulse.com
 http://www.avtechpulse.com/

 BOX 5120, LCD MERIVALE
 OTTAWA, ONTARIO
 CANADA K2C 3H4
 TEL: (613) 226-5772
 FAX: (613) 226-2802

"-B" Functional Test & Calibration Certificate

Date of test:	November 24, 2003					Tester:	MJC
Programmed model name:	AVPP-2-B-P						
Programmed serial number:	10783						
Firmware revision:	2.54						
Internal trigger checked at:	10 Hz	100 Hz	1 kHz	10 kHz	100 kHz		
Actual measured output ¹ :	9.97 Hz	99.7 Hz	0.997 kHz	10.01 kHz	100.1 kHz		
External trigger checked:	Yes				Gate checked:	Yes	
Manual trigger checked:	Yes						
Pulse compression checked:	Yes			Low Amplitude PW Distortion Nullled:		N/A	
Pulse width checked at:	1 ns	10 ns	100 ns			10 kHz, +20V to 50Ω	
Actual measured output ² :	1.1 ns	10.3 ns	100 ns				
PWin = PWout mode checked:	N/A			DC mode checked:		N/A	
Duty Cycle Limit:	N/A						
Delay nullled:	Yes						
Delay checked at:	100 ns	1 us	10 us			10 kHz, +20V to 50Ω	
Actual measured output ¹ :	99.8 ns	1.007 us	10.09 us				
Double pulse checked:	N/A						
Invert mode checked:	N/A						
ECL/TTL modes checked:	N/A						
Zout switch checked:	N/A						
Amplitude checked at:	3 ns, +5V	100 ns, +10V	3 ns, +15V	100 ns, +20V	10 kHz, to 50Ω		
Actual measured output ² :	+5.1V	+10.3V	+14.5V	+20.3V			
Amplitude polarity:	+						
Zout calibration:	N/A						
Electronic amplitude control:	N/A						
External amplify mode:	N/A						
Bleeder resistors adequate:	N/A						
Burst mode:	N/A						
Monitor V/I Ratio:	N/A			Monitor offset nullled:			
LCD Monitor calibrated:	N/A						
Offset checked at:	N/A						
Actual measured output ² :	N/A						
Offset nullled (output on):	N/A			Amplitude-dependent offset nullled:			
Offset nullled (output off):	N/A						
RS-232 checked:	Yes						
LCD pull-ups installed:	Yes						
PCB 108G resistor updates:	Yes						
PN trigger pull-downs installed:	N/A						
Sync pulse width checked:	200 ns nominal						
Circuit Boards:	PS:	93	Main:	108G			
Overload Trigger Resistance:	Trips at:	N/A	Installed:	N/A			
DC fuses:	Positive:	N/A	Negative:	N/A			
AC Current:	Quiescent:	0.35A @ 115V	Max. Load:	0.38A @ 115V			
		0.17A @ 230V		0.18A @ 230V			
AC fuse:	1A						
1.5 kV RMS, 5 second Hypot Test:	OK						
25A RMS Ground Continuity Test:	OK						
Fan operational:	Yes						
Photographed:	Yes						

¹ Checked with: Fluke PM6681 Counter (S/N 9446 066 81016), referenced to Datum ExacTime 9390-6000 (S/N 4461) GPS Frequency Reference

² Checked with: Tektronix TDS3052 digital oscilloscope (S/N B014783) for PW ≥ 5 ns, Tektronix 7704A/7S11/7T11/S4 sampling oscilloscope (Cal. Label 112506) for PW < 5 ns.

P:\b-calibration\sn10783,AVPP-2-B-P.sxw