

INSTRUCTIONS

MODEL AVG IMPULSE GENERATOR

S.N.:

TABLE OF CONTENTS

WARRANTY.....

Fig. 1: IMPULSE GENERATOR TEST ARRANGEMENT.....

OPERATING INSTRUCTIONS.....

WARRANTY

Avtech Electrosystems Ltd. warrants products of its manufacture to be free from defects in material and workmanship under conditions of normal use. If, within one year after delivery to the original owner, and after prepaid return by the original owner, this Avtech product is found to be defective, Avtech shall at its option repair or replace said defective item. This warranty does not apply to units which have been disassembled, modified or subjected to conditions exceeding the applicable specifications or ratings. This warranty is the extent of the obligation or liability assumed by Avtech with respect to this product and no other warranty or guarantee is either expressed or implied.

Fig. 1: IMPULSE GENERATOR TEST ARRANGEMENT

OPERATING INSTRUCTIONS

- 1) The bandwidth capability of components and instruments used to display the pulse generator output signal (attenuators, cables, connectors, etc.) should exceed ten gigahertz.
- 2) The use of 60 dB attenuator will insure a peak input signal to the sampling scope of less than one Volt.
- 3) In general, the pulse generator trigger delay control should be set in the 100 ns range. Other settings should be as shown in the above diagram. The impulse generator output is delayed with respect to the trigger input signal by about 70 ns. (typically).
- 4) The impulse generator can withstand an infinite VSWR on the output port.
- 5) The output amplitude is controlled by the one turn AMP control.
- 6) The monitor output port (M) provides a coincident attenuated (x10) replica of the main output to a 50 Ohm load. (option).
- 7) For additional assistance:

Tel: (613) 226-5772

Fax: (613) 226-2802

E-mail: info@avtechpulse.com