



**AVTECH ELECTROSYSTEMS LTD.**

NANOSECOND WAVEFORM ELECTRONICS  
SINCE 1975

P.O. BOX 265  
OGDENSBURG, NY  
U.S.A. 13669-0265  
TEL: (315) 472-5270  
FAX: (613) 226-2802

TEL: 1-800-265-6681  
FAX: 1-800-561-1970  
U.S.A. & CANADA

e-mail: [info@avtechpulse.com](mailto:info@avtechpulse.com)

BOX 5120 STN. F  
OTTAWA, ONTARIO  
CANADA K2C 3H4  
TEL: (613) 226-5772  
FAX: (613) 226-2802

**INSTRUCTIONS**

**MODEL AVR-D2-C PULSE GENERATOR**

**S.N. :**

### WARRANTY

Avtech Electrosystems Ltd. warrants products of its manufacture to be free from defects in material and workmanship under conditions of normal use. If, within one year after delivery to the original owner, and after prepaid return by the original owner, this Avtech product is found to be defective, Avtech shall at its option repair or replace said defective item. This warranty does not apply to units which have been disassembled, modified or subjected to conditions exceeding the applicable specifications or ratings. This warranty is the extent of the obligation assumed by Avtech with respect to this product and no other warranty or guarantee is either expressed or implied.

### TECHNICAL SUPPORT

Phone: 613-226-5772 or 1-800-265-6681


Fax: 613-226-2802 or 1-800-561-1970

E-mail: [info@avtechpulse.com](mailto:info@avtechpulse.com)

World Wide Web: <http://www.avtechpulse.com>

Fig. 1

PULSE GENERATOR TEST ARRANGEMENT



Notes:

- 1) The bandwidth capability of components and instruments used to display the pulse generator output signal (attenuators, cables, connectors, etc.) should exceed 1000 MHz.
- 2) The use of 50 dB attenuator (for channel A but 20 dB for channel B) at the scope vertical input channel will insure a peak input signal to the scope of less than one Volt (necessary only if sampling scope used). If a high impedance real time scope is used, the pulse generator should be terminated using a shunt 50 Ohm resistor. Note that channels A and B both require 50 Ohm termination when operating. Note that AVTECH can supply some test jigs. Call for further information.
- 3) The TRIG output channel provides TTL level signals. To avoid overdriving the TRIG input channel of some scopes, a 30 dB attenuator should be placed at the input to the scope trigger channel. The TRIG output precedes the main output when the front panel ADVANCE-DELAY switch is in the ADVANCE position. The TRIG output lags the main output when the switch is in the DELAY position.
- 4) The desired output polarity is selected by means of the front panel POLARITY switch.
- 5) To obtain a stable output display the PW and PRF controls on the front panel should be set mid range. The front panel TRIG toggle switch should be in the INT position. The DELAY controls and the scope triggering controls are then adjusted to obtain a stable output. The scope may then be used to set the desired PRF by rotating the PRF controls.
- 6) CAUTION: The output duty cycle for the A output must not exceed 10% (or the output stage may be damaged). For example, at the maximum pulse width of 20 us, the PRF must not exceed 5 kHz. For pulse width of 2 us or less the PRF may be as high as 50 kHz.

AVR units with a serial number higher than 5600 are protected by an automatic overload protective circuit which controls the front panel overload light. If the unit is overloaded (by operating at an exceedingly high duty cycle or by operating into a short circuit), the protective circuit will turn the output of the instrument OFF and turn the indicator light ON. The light will stay ON (i.e. output OFF) for about 5 seconds after which the instrument will attempt to turn ON (i.e. light OFF) for about 1 second. If the overload condition persists, the instrument will turn OFF again (i.e. light ON) for another 5 seconds. If the overload condition has been removed, the instrument will turn on and resume normal operation. Overload conditions may be removed by:

- 1) Reducing PRF (i.e. switch to a lower range)
- 2) Reducing pulse width (i.e. switch to a lower range)
- 3) Removing output load short circuit (if any)

Note that the light may illuminate when the prime power is first applied. The light will extinguish after a few seconds and the unit will then operate normally. Also note that triggering of the output stage is inhibited if the peak output current exceeds one Ampere.

- 7) The output pulse width for output A is controlled by means of the front panel one turn PW A control and the two-position range switch. The pulse width for the B output is fixed at 15 ns.
- 8) The output pulse amplitude for output A is controlled by means of the front panel ten turn AMP A control. The amplitude for the B output is fixed at 2 Volts.
- 9) The DC offset to outputs A and B is controlled by the 10 turn front panel offset control and the two position offset ON-OFF switch. Note that the DC offset is zero for the pot control set near mid range while the offset magnitude is maximum for the pot fully CW or fully CCW.
- 10) An external clock may be used to control the output PRF of the AVR unit by setting the front panel TRIG toggle switch in the EXT position and applying a 0.2 us (approx.) TTL level pulse to the TRIG BNC connector input. For operation in this mode, the scope time base must also be triggered by the external clock rather than from the TRIG output.

11) CAUTION:


- a) Both outputs A and B are designed to operate into 50 Ohms so the switching time test circuit should present an input resistance of this magnitude. Note that AVTECH can supply some test jigs. Call AVTECH for more information.
  - b) At maximum duty cycle, output A will provide nearly 2 Watts average power so the test circuit must be capable of dissipating this power.
  - c) The DC offset on output A will provide up to 4.5 Watts to a DC load of 50 Ohms. It may be necessary to place DC blocking capacitors in the test circuit to limit the DC power dissipation.
  - d) An audible hum may be evident when the DC offset is set near maximum for output A and the output pulse width is near maximum. This hum is normal.
- 12) EA Option. To voltage control the output amplitude of channel A, set the rear panel AMP switch in the EXT position and apply 0 to +10 Volts to the "A" BNC connector ( $R_{IN} \geq 10K$ ).
- 13) EW Option. To voltage control the output pulse width of channel A, set the rear panel PW switch in the EXT position and apply 0 to +10 Volts to the "A" BNC connector ( $R_{IN} \geq 10K$ ).
- 14) EO Option. To voltage control the DC offset on channel A or B, set the rear panel OS switch in the EXT position and apply 0 to +10 Volts to the "A" BNC connector ( $R_{IN} \geq 10K$ ).
- 15) EP Option. To voltage control the output polarity of channel A or B, set the rear panel POL switch in the EXT position and apply 0 or +5 Volts to the "A" BNC connector ( $R_{IN} \geq 10K$ ). 0 Volts will provide a positive output pulse while +5 Volts will provide a negative output pulse.
- 16) ER Option. To voltage control the output channel A or B, set the rear panel ER switch in the EXT position and apply 0 or +5 Volts to the "A" BNC connector ( $R_{IN} \geq 10K$ ). 0 Volts will provide the "A" output pulse while +5 Volts will provide the "B" output pulse.
- 17) M Option. The monitor output (-M) provides a 20 dB attenuated coincident replica of the channel A and channel B output.

18) The unit can be converted from 120 to 240V 50-60 Hz operation by adjusting the voltage selector card in the rear panel fused voltage selector-cable connector assembly.

19) For additional assistance:

Tel: 613-226-5772

Fax: 613-226-2802



FRONT PANEL CONTROLS

Fig. 2

- (1) ON-OFF Switch. Applies basic prime power to all stages.
- (2) PRF Control. Controls PRF as follows:


|         |        |    |        |
|---------|--------|----|--------|
| RANGE 1 | 5 Hz   | to | 50 Hz  |
| RANGE 2 | 50 Hz  | to | 500 Hz |
| RANGE 3 | 500 Hz | to | 5 kHz  |
| RANGE 4 | 5 kHz  | to | 50 kHz |
- (3) DELAY Control. Controls the relative delay between the reference output pulse provided at the TRIG output (4) and the main output (5). This delay is variable over the range of 0 to 2.0 us and 2.0 to 20.0 us. The TRIG output precedes the main output when the ADVANCE-DELAY switch is in the ADVANCE position and lags when the switch is in the DELAY position.
- (4) TRIG Output. This output is used to trigger the scope time base. The output is a TTL level 100 ns (approx.) pulse capable of driving a fifty Ohm load.
- (5) OUT Connector. BNC connector provides A or B output to a fifty Ohm load (controlled by channel A-B range switch (9)).
- (6) PW A Control. A ten turn control and two-position range switch which varies the output pulse width from 200 ns to 2.0 us and 2 us to 20 us.
- (7) AMP A Control. A ten turn control which varies the output pulse amplitude from 0 to 30 V to a fifty Ohm load.
- (8) POLARITY Control. Controls polarity of output pulse.
- (9) Channel A-B selector. With two-position switch in A position output A is active (at (5)). With switch in B position the output B is active (at (5)).
- (10) The DC offset to outputs A and B is controlled by the
- (11) 10 turn front panel offset control (10) and the two-position offset ON-OFF switch (11). Note that the DC offset is zero for the pot control set near mid-range while the offset magnitude is maximum for the pot fully CW or fully CCW. The max DC offset for channel A is 0 to  $\pm 15$  Volts while the range for channel B is 0 to  $\pm 1$  Volt.

- (12) EXT-INT Control. With this toggle switch in the INT position, the PRF of the AVR unit is controlled via an internal clock which in turn is controlled by the PRF and PRF FINE controls. With the toggle switch in the EXT position, the AVR unit requires a 50 ns (or wider) TTL level pulse applied at the TRIG input in order to trigger the output stages. In addition, in this mode, the scope time base must be triggered by the external trigger source.
- (13) OVERLOAD. AVR units with a serial number higher than 5600 are protected by an automatic overload protective circuit which controls the front panel overload light. If the unit is overloaded (by operating at an exceedingly high duty cycle or by operating into a short circuit), the protective circuit will turn the output of the instrument OFF and turn the indicator light ON. The light will stay ON (i.e. output OFF) for about 5 seconds after which the instrument will attempt to turn ON (i.e. light OFF) for about 1 second. If the overload condition persists, the instrument will turn OFF again (i.e. light ON) for another 5 seconds. If the overload condition has been removed, the instrument will turn on and resume normal operation. Overload conditions may be removed by:
- 1) Reducing PRF (i.e. switch to a lower range)
  - 2) Reducing pulse width (i.e. switch to a lower range)
  - 3) Removing output load short circuit (if any)


When the prime power is first applied the light may illuminate. After a few seconds the light will extinguish and the unit will then operate normally. Note also that triggering of the output stage is inhibited if the peak output current exceeds 1.0 Amp.

Fig. 3

BACK PANEL CONTROLS



- (1) FUSED CONNECTOR, VOLTAGE SELECTOR. The detachable power cord is connected at this point. In addition, the removable cord is adjusted to select the desired input operating voltage (120/240V, 50-60 Hz). The unit also contains the main power fuse (0.5A SB).
- (2) 2.0A SB. Fuse which protects the output stage if the output duty cycle rating is exceeded.
- (3) EA Option. To voltage control the output amplitude of channel A, set the rear panel AMP switch in the EXT position and apply 0 to +10 Volts to the "A" BNC connector ( $R_{IN} \geq 10K$ ).
- (4) EW Option. To voltage control the output pulse width of channel A, set the rear panel PW switch in the EXT position and apply 0 to +10 Volts to the "A" BNC connector ( $R_{IN} \geq 10K$ ).
- (5) EO Option. To voltage control the DC offset on channel A or B, set the rear panel OS switch in the EXT position and apply 0 to +10 Volts to the "A" BNC connector ( $R_{IN} \geq 10K$ ).
- (6) EP Option. To voltage control the output polarity of channel A or B, set the rear panel POL switch in the EXT position and apply 0 or +5 Volts to the "A" BNC connector ( $R_{IN} \geq 10K$ ). 0 Volts will provide a positive output pulse while +5 Volts will provide a negative output pulse.
- (7) ER Option. To voltage control the output channel A or B, set the rear panel ER switch in the EXT position and apply 0 or +5 Volts to the "A" BNC connector ( $R_{IN} \geq 10K$ ). 0 Volts will provide the "A" output pulse while +5 Volts will provide the "B" output pulse.
- (8) M Option. The monitor output (-M) provides a 20 dB attenuated coincident replica of the channel A and channel B output.



AVR-D2-EA-EW-EP-C-EO-M

OUT  
CHOKE

SYNC

CHANNEL

7824(1)

7815(1)

OFF  
ON  
OFFSET

300 ufd

PS-22

7484(2)

2200 ufd

PRF DELAY 25K

7815(2)

7433

120

EXT INT

OUT B

A

EXT INT

OT 5K

7815(2)

2.2K

4.7K

4.7K

680

2200

EXT INT

A

AMP A 5K

4733

EXT INT

33K 10K

PGA N

PGA P

7815(2)

EXT INT

A

7806

INT POS NEG

POLARITY

7915

EXT INT

RSM-2D +24

OS

OUT

CHOKE

820 +47

LOW PW A

HIGH PW A

7815(2)

4733

PW A 5K

EXT INT

A

DELAY RANGE

3) 0.55

2) 2.2

1) 22

INT EXT

INT EXT

LEAD LAG

PRF RANGE

CL

INT EXT

## SYSTEM DESCRIPTION AND REPAIR PROCEDURE

The AVR-D2-C consists of the following basic modules:

- 1) AVR-D2-PGA pulse generator modules (-P and -N)
- 2) AVR-D2-PSA-PWA power supply module
- 3) AVR-D2-PGB-OT pulse generator-offset module
- 4) AVR-D2-PS-22 power supply module
- 5) AVR-D2-OS offset module
- 6) AVR-D2-CL clock module
- 7) +24V power supply board

The modules are interconnected as shown in Fig. 4. The clock module controls the output PRF and the relative delay between the main output and the SYNC outputs. The PG pulse generator modules generate the output pulse. In the event of an instrument malfunction, it is most likely that the rear panel 2.0A SB fuse or some of the output switching elements (SL5T) may have failed due to an output short circuit condition or to a high duty cycle condition. The switching elements may be accessed by removing the cover plates on the bottom side of the instrument. NOTE: First turn off the prime power. The elements may be removed from their sockets by means of a needle nosed pliers. The SL5T is a selected VMOS power transistor in a TO 220 packages and may be checked on a curve tracer. If defective, replacement units should be ordered directly from Avtech. When replacing the SL5T switching elements, take care to insure that the short lead (of the three leads) is adjacent to the black dot on the chassis. If the switching elements are not defective, then the four Phillips screws on the back panel should be removed. The top cover may then be slid off and operation of the clock and power supply modules should be checked. The clock module is functioning properly if:

- a) 0.1 us TTL level outputs are observed at pins 2 and 3.
- b) The PRF of the outputs can be varied over the range of 50 Hz to 50 kHz using the PRF controls.
- c) The relative delay between the pin 2 and 3 outputs can be varied by at least 20 us by the DELAY controls.

The sealed clock module must be returned to Avtech for repair or replacement if the above conditions are not observed. The power supply board generates +24V DC to power the other modules. If the voltage is less than +24V, turn off the prime power and unsolder the lead from the 7824 regulator chip on the power supply board. Solder a 100 Ohm 5 Watt resistor to the 7824 output to ground and turn on the prime power. A voltage of +24 Volts should be read. If the voltage is less then the power supply board is defective and should be repaired or replaced.

Aug. 21/96

Edition D

-PN

Disk: AVR-D

-EA

Frame: D2CD.INS

-EW

-EO

-EP

-ER

-M